

CHECKLIST

Before summer starts

Ventilation:

Set up the summertime at the regulations appliance ventilation

Rewind the ventilation to level 1 or switch it totally off (but then there has to be regular window-ventilation)

Air heating has to be switched off at the regulation appliance

Air filter on the ventilation appliance has to be renewed once a year. You only have to look after that, if there is a message on the ventilation appliance.

Thermostat valves have to be set „0“.

F1 switch has to be actuated (the best time ist the day of changing the clocks to summertime)

Cleaning of the drains

Before winter starts

Ventilation:

Wintertime has to be set at the regulation appliance ventilation

Set ventilation to level 2 (can be shortly set to level 3, if required, but don't forget to rewind it to level 2)

Control the programming of the time switch clock

Information: with the help of the time switch clock you decide when the ventilation system runs at level 1

Heating:

The thermostat valves have to be set on a normal level (level 3 is about 20 – 21 degrees Celsius)

The radiator in the bathroom has to be ventilated, if it's not permanently warm and if strange noises can be heard (the water supply runs automatically)

The F1 switch has to be actuated (the best time ist the day of changing the clocks to wintertime)